

International Conference on Fast Reactors and Related Fuel Cycles: Next Generation Nuclear Systems for Sustainable Development (FR17)



Contribution ID: 416

Type: POSTER

INTEGRATED R&D TO VALIDATE INNOVATIVE EMERGENCY HEAT REMOVAL SYSTEM FOR BN-1200 REACTOR

Wednesday, June 28, 2017 5:50 PM (1h 10m)

Decay heat removal from BN-1200 to atmospheric air is performed using passive DHRS. Several innovative solutions are applied during the DHRS development:

- hydraulic connection of the decay heat exchanger (DHX) with reactor high pressure plenum, installation of check valve at DHX outlet;
- application of slide valve of air heat exchanger with passive elements;
- natural circulation in all DHRS circuits.

Set of experimental research is performed at facilities with water and sodium:

- hydraulic testing of several options of DHX check valve are performed using scaled-down models;
- main characteristics of the check valve are determined using full-scale model;
- in the closed position of check valve diffusion like process was investigated (long-term testing);
- experimental studies of thermohydraulic characteristics are performed using scaled-down reactor model with one DHRS loop.

Integrated computational validation of DHRS effectiveness is performed using new generation code SOCRAT-BN.

Country/Int. Organization

Russia/JSC "Afrikantov OKBM"

Primary author: Mr PAKHOLKOV, Vasilii (JSC "Afrikantov OKBM")

Presenter: Mr PAKHOLKOV, Vasilii (JSC "Afrikantov OKBM")

Session Classification: Poster Session 2

Track Classification: Track 6. Test Reactors, Experiments and Modeling and Simulations