

Overview of the Versatile Test Reactor Safety Analysis



APRIL 20, 2022

T. Sumner, T. H. Fanning, and J. W. Thomas

Note: Information regarding site location is **preliminary**. The decision for site location is determined via DOE acquisition processes that have not yet been completed.




- Versatile Test Reactor:
 - Fast spectrum test reactor design
 - 300 MWth
 - Sodium coolant
 - Metallic fuel
 - Pool type
- SAS4A/SASSYS-1 model represents:
 - Core
 - Primary heat transport system
 - Secondary heat transport system
 - Reactor vessel auxiliary cooling system
 - Reactor protection system
- Protected Transient Scenarios
 - Evaluated to demonstrate system's response to various initiating events
 - Protected loss of heat sink
 - PLOHS
 - Protected loss of flow/station blackout
 - PLOF/PSBO
 - Protected transient overpower
 - PTOP
 - Transient initiated at nominal full power, full flow conditions
 - BOC and EOC

SAS4A/SASSYS-1 Core Model



SAS4A/SASSYS-1 Heat Rejection System Model

- PRIMAR-4 module used to model VTR heat transport system
 - Primary, secondary, and RVACS systems



Metrics

- Demonstrate safe shutdown of reactor
- Maintain coolable fuel pin geometry
- PTOP, PSBO, PLOHS
 - AOOs or DBEs?
 - Subject to PRA results
 - Tentatively assumed to be AOO
 - For PRISM PSID, would be evaluated against ASME Service Level B
- Note: These metrics are preliminary
 - Based on expectation that these are bounding events
 - Will depend on results of PRA & uncertainties



Criteria

- Control Rods:
 - Establish and maintain subcriticality
- Cladding:
 - Cladding temp below 649°C
 - Service Level B limit
 - Both peak and long-term
 - Precludes eutectic formation
- Coolant:
 - Pools remain below 649°C
 - Service Level B limit
 - Both peak and long-term
- Fuel melting and coolant boiling margins also assessed
 - But specific limits not defined



Results

Protected Station Blackout: Definition

- Loss of electrical power to all plant systems
- Primary pumps trip
- Secondary pumps trip
- SAHX heat rejection lost




Protected Station Blackout: Short-Term





Protected Transient Overpower: Definition

- Withdrawal of one control rod
- RPS functions as designed
- SAHX heat rejection eliminated following plant trip
- Simulation Transient Initiator:
 - 95.7¢ reactivity insertion (BOC)
 - Average insertion rate: 0.5¢/s
 - Insertion speed: 2.1 mm/s




Protected Transient Overpower: Short-Term





Protected Loss of Heat Sink: Definition

- Simultaneous trip of all secondary pumps
- RPS functions as designed
- Simulation Transient Initiator:
 - Secondary pumps trip
 - SAHX heat rejection assumed lost as well



Protected Loss of Heat Sink: Short-Term



Summary & Conclusions

Summary & Conclusions


Beginning of Cycle

	Initial Value	PTOP Value	PLOHS Value	PSBO Value
Peak Fuel Temp.	769°C	822°C	769°C	774°C
Peak Cladding Temp.	553°C	582°C	560°C	599°C
Peak In-Core Sodium Temp.	528°C	553°C	537°C	588°C
Peak Bulk Sodium Temp.	500°C	503°C	501°C	501°C
Fuel Melting Margin	350°C	297°C	350°C	345°C
Sodium Boiling Margin	430°C	396°C	410°C	383°C
Bulk Coolant Margin	149°C	146°C	148°C	148°C
Cladding Margin	96°C	67°C	89°C	50°C

- Primary heat transport system:
 - Able to transition quickly & effectively to natural circulation
- Reactor Protection System:
 - Dominates transient behaviors and inherent feedbacks
- RVACS:
 - Provides sufficient heat rejection capability
- Large margins for all criteria predicted for all analyzed transients
- VTR being designed with a high level of safety

End of Cycle

	Initial Value	PLOHS Value	PSBO Value
Peak Fuel Temp.	751°C	751°C	756°C
Peak Cladding Temp.	547°C	555°C	591°C
Peak In-Core Sodium Temp.	520°C	530°C	578°C
Peak Bulk Sodium Temp.	500°C	501°C	501°C
Fuel Melting Margin	368°C	368°C	363°C
Sodium Boiling Margin	438°C	411°C	393°C
Bulk Coolant Margin	149°C	148°C	148°C
Cladding Margin	102°C	94°C	58°C



**Thank you for
your attention**



**SOLVING ENERGY CHALLENGES
THROUGH SCIENCE**

inl.gov/vtr

vtr@inl.gov