

BLIND PHASE RESULTS FOR TRANSIENT SIMULATIONS OF LOFWOS TEST #13

TYLER SUMNER, ANTON MOISSEYTSEV Argonne National Laboratory

DAVID WOOTAN Pacific Northwest National Laboratory

International Conference on Fast Reactors and Related Fuel Cycles: Sustainable Clean Energy for the Future (FR22) 19–22 April 2022, Vienna, Austria



FFTF AND THE IAEA CRP



U.S. DEPARTMENT OF ENERGY Argonne National Laboratory is a U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.



FAST FLUX TEST FACILITY

- Fast Flux Test Facility
 - 400 MWt
 - Oxide-fueled
 - Sodium-cooled
 - Built at Hanford site in Washington
 - Built for testing & development of advanced fuels and materials
- Passive Safety Testing program
 - Goals included:
 - Confirming safety margins
 - Data for code validation
 - Demonstrating inherent and passive safety benefits of design features
 - Included 13 Loss of Flow Without Scram (LOFWOS) tests
 - Other tests include static tests to measure feedbacks





IAEA CRP ON FFTF

- Four year Coordinated Research Project (CRP)
 - LOFWOS Test #13:
 - Demonstrated effectiveness of GEMs as shutdown device
 - Limited free bow core restraint system
 - Benchmark specification developed by Argonne and PNNL
 - 25 participants
 - 20 submitted blind phase transient results
- CRP led by Argonne and PNNL



Participants:	
CIAE (China)	IBRAE (Russia)
INEST (China)	IPPE (Russia)
NCEPU (China)	CIEMAT (Spain)
XJTU (China)	KTH (Sweden)
CEA (France)	EPFL (Switzerland)
HZDR (Germany)	PSI (Switzerland)
KIT (Germany)	Argonne (USA)
IGCAR (India)	US NRC (USA)
NINE (Italy)	Texas A&M (USA)
Uni. of Rome (Italy)	TerraPower (USA)
JAEA (Japan)	PNNL (USA)
KAERI (Korea)	Zachry Eng. (USA)
NRG (Netherlands)	



LOFWOS TEST #13

- Performed on July 18, 1986
- Initiated at 50% power & 100% flow
- Transient Initiators:
 - Primary pumps simultaneously tripped
 - Secondary pumps not tripped
 - DHX fan speed reduced ~1 minute earlier
- PPS modified to prevent premature control rod insertion
- Transient Benchmark Boundary Conditions:
 - Primary flow rates

Argonne National Laboratory is a U.S. Department of Energy laboratory managed by UChicago Argonne, LLC

- Secondary pump speeds
- DHX sodium outlet temperatures





BENCHMARK PARAMETERS TO CALCULATE

- Measured Test Data
 - Fission power
 - Row 2 PIOTA & Row 6 PIOTA outlet temperatures
 - Primary loop mass flow rates
 - Primary loop hot leg temperatures
 - Primary loop cold leg temperatures
 - Secondary loop hot leg temperatures
 - Secondary loop cold leg temperatures
 - Primary pump discharge pressures for all loops
- Calculated Test Data
 - Total power
 - Decay heat
 - Net reactivity

- For Code-to-Code Comparison
 - Reactivity feedbacks
 - Row 2 PIOTA & Row 6 PIOTA mass flow rates
 - Peak fuel, cladding, & coolant temps
 - IHX primary-side inlet & outlet temperatures
 - IHX secondary-side inlet & outlet temperatures
 - Average reactor vessel inlet & outlet temperatures
- Steady-State Parameters
 - Average fuel temperature
 - Row 2 axial fuel temperature distribution
 - Row 2 axial cladding temperature distribution
 - Row 2 axial coolant temperature distribution
 - Row 6 axial fuel temperature distribution
 - Row 6 axial cladding temperature distribution
 - Row 6 axial coolant temperature distribution





RESULTS



ENERGY Argonne National Laboratory is a U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.



TOTAL POWER









DECAY HEAT



Generative Argonne National Laboratory is a U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.



NET REACTIVITY



W.S. DEPARTMENT OF U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.



PEAK FUEL TEMPERATURES



U.S. DEPARTMENT OF U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.



PRIMARY LOOP #1 MASS FLOW RATE







COOLANT OUTLET TEMPERATURES



Row 2 PIOTA

Row 6 PIOTA

Argonne National Laboratory is a U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.



PRIMARY LOOP #1 HOT LEG TEMPERATURE







SUMMARY

- IAEA CRP for benchmark analysis of FFTF LOFWOS Test #13
- Unprotected loss of flow test initiated at half power and full flow
- Blind phase of the CRP concluded in October 2020
- Blind phase transient simulation predictions evaluated for agreement with:
 - Measured test data
 - Other participant predictions
- Blind phase results:
 - Provide confidence that many participants captured the transient progression of the test well
 - Provide key information for improving transient predictions
 - Modeling improvements during open phase focused on reducing discrepancies between measured and predicted results





ACKNOWLEDGEMENTS

- The work has been carried out jointly by UChicago Argonne, LLC, Operator of Argonne National Laboratory and Pacific Northwest National Laboratory. Argonne National Laboratory's work is supported by U.S. Department of Energy (DOE) under Contract number DE-AC02-06CH11357. Pacific Northwest National Laboratory work is supported by U.S Department of Energy (DOE) under Contract number DE-AC05-76RL01830. The work described in this paper has been funded by the DOE Advanced Reactor Technologies (ART) program.
- The authors are thankful to
 - Brian Robinson, the ART Program Manager
 - Robert N. Hill and Bo Feng, the National Technical Directors for the ART Program Fast Reactors Campaign
 - Tanju Sofu, the DOE-NE ART Program Fast Reactor Methods Technical Area Lead
 - Vladimir Kriventsev and the IAEA for conducting the FFTF Coordinated Research Project





THANK YOU FOR YOUR ATTENTION



U.S. DEPARTMENT OF ENERGY Argonne National Laboratory is a U.S. Department of Energy laboratory managed by UChicago Argonne, LLC.

