

STATUS OF JRR-3 AFTER GREAT EAST JAPAN EARTHQUAKE

Tuesday, 17 November 2015 10:00 (20 minutes)

JRR-3 at Tokai site of JAEA was in its regular maintenance period, when the Great East Japan Earthquake took place on 11th March 2011. The reactor building with the solid foundations and the equipment important to safety survived the earthquake without serious damage, and no radioactive leakage has been occurred. Recovery work, check and test of the integrity for all components have been carried out. In response to the accident at Fukushima Daiichi NPS, the new safety standards for research and test reactor facilities came into force on December 18, 2013. The evaluation of natural disasters and prevention of spread of accidents beyond design basis mainly were enhanced in the standards. We have completed the necessary checks and assessments, and submitted an application for reviewing if JRR-3 complies with the new standards to the Nuclear Regulation Authority on September 26, 2014.

Organization

Japan Atomic Energy Agency

Country

Japan

Primary authors: Mr TOMOAKI, Kato; Mr WADA, Shigeru (Japan Atomic Energy Agency); Mr MURAYAMA, Yoji (Japan Atomic Energy Agency); Mr TORII, Yoshiya (Japan Atomic Energy Agency)

Presenter: Mr TOMOAKI, Kato

Session Classification: Safety of Research Reactors

Track Classification: Safety of Research Reactors